



MOUNTAINS RECREATION & CONSERVATION AUTHORITY
 King Gillette Ranch
 26800 Mulholland Hwy
 Calabasas, California 91302

MRCA Policy for Generators

Permittees must notify Ventura County, LA County, or LA City Fire Departments regarding events if a generator of 7500 watts is to be used.

It is the responsibility of the Permittee to comply if the following conditions apply:

Generators equal to or under 7500 watts (putt-putt)	Requires a minimum of three (3) fire extinguishers on site, at all times, for each putt-putt, minimum 5lb each. Permittee or vendor must assign a staff member or crew to oversee putt-putt
Generators above 7500 watts Any generator usage in Summer + early Fall months (July, August, September, October)	Requires a Fire Marshal and a 4,000-gallon water truck

The Fire Marshal's final directive regarding the event conditions supersedes the requirements listed above.

Contacts:

For Upper Las Virgenes Ranch/Canyon Open Space Preserve

Ventura County Fire Department
 Contact: Lori Ross
 Email: lori.ross@ventura.org
 Phone: 805.947.8535

For King Gillette Ranch

Fire truck and FSO
 Inspector Craig Terry
 LA County Fire / Calabasas Fire Prevention
 Office: 818-880-0343
 Email: craig.terry@fire.lacounty.gov
 Monday to Thursdays only 7am to 9.30am